


CERTIFICATE

Certificate holder	Konti Hidroplast Ul. Industriska B.B. 1480 Gevgelija NORTH MACEDONIA
Production facility	Gevgelija, Republic of Macedonia
Product	Pressure pipes made from Polyethylene (PE) for alternative installation techniques - PE 100-RC
Classification	EG 926.3, Outer diameter 250 mm up to 630 mm
Type, Model	PE-HD-Rohr "Konti"
Remarks to the type	PAS 1075 Type 2 3L - TW / Basis EN 12201-2
Testing basis	PAS 1075:2009-04 Certification Scheme Plastic Piping Systems (Pressure Pipes and Fittings) (2017-05)
Mark of conformity	
Registration No.	P1R0667
Valid until	2029-07-31
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

2024-07-05


Dipl.-Phys. Carlo Seiser
Head of Certification Body

ANNEX

Page 1 of 1

Certificate	P1R0667 dated 2024-07-05
Technical Data	<p>PAS 1075 Type 2 3 L - TW Basis EN 12201-2</p> <p>Outer diameter 250 mm up to 630 mm Maximum wall thickness inner layer 20,5 mm</p> <p>Material: PE 100-RC</p> <p>Type: see production facility related material list</p> <p>Colour inner layer: royal blue Colour middle layer: black Colour outer layer: royal blue</p> <p>Basis: DVGW CERT # DW-8148C00245</p> <p>Operating over pressure burstlining: see Certification Scheme Plastic piping systems (Pressure pipes and fittings)(2017-05) Annex O 14</p>
Testing laboratory/ Inspection body	Hessel Ingenieurtechnik GmbH Am Münsterwald 3 52159 Roetgen GERMANY
Test report(s)	R24 06 4605-A1-A2_PLT+ dated 2024-01-19 R24 06 4605-B4-B5-B6_PLT+ dated 2024-01-19 R24 06 4605-B_ACT dated 2024-01-19 R24 06 4605-C_ACT dated 2024-01-19 R24 03 4605-D_WA_final dated 2024-06-21

